CSA	INTERNATIONAL

CERTIFICATION RECORD

The company named below has been authorized by CSA to represent the products listed in this record as "CSA Certified" and to affix the CSA Mark to these products according to the terms and conditions of the CSA Service Agreement and applicable CSA program requirements (including additional Markings).

- File No: 029862 0 000
- Class No: 1421 01 FUSES Cartridge Type Non-renewable

SUBMITTOR

4501292 Littelfuse, Inc. 800 E Northwest Hwy Des Plaines, IL 60016-3096 USA

FACTORIES

- Littelfuse, Inc. 4501292 800 E Northwest Hwy Des Plaines, IL 60016-3096 USA
- 4548889 Littelfuse Phils., Inc. Lima Technology Center Special Economic Zone Lipa City-Malvar Batangas, Philippines

July 9, 2002(Replaces:June 7, 1989)

- Type NLN or 563, 12A and less, and 70-600A, 250V ac and less, IR250-10kA.
- Type NLS or 564, 600A and less, 600V ac and less, IR600-10kA.
- Type NLNK, 65-400A, 250V ac and less, IR250-10kA.
- Type NLSK, 100A and less, 600V ac and less, IR600-10kA.
- Type NLNP, 60A and less, 250V ac and less, IR250-10kA, thermal Type P.
- Type FLN, 600A and less, 250V ac and less, IR250-10kA.
- Type FLS, 600A and less, 600V ac and less, IR600-10kA.

TO THE REQUIREMENTS OF CSA STD. C22.2 NO 59.1-M1987 AND E.C.N. 555:

• Type NLKP, 15-60A, 250V ac and less, IR250-10kA, thermal Type P.

/vem

DQD No. 548 99/04/06